

# Senate Bill 95

Printed pursuant to Senate Interim Rule 213.28 by order of the President of the Senate in conformance with pre-session filing rules, indicating neither advocacy nor opposition on the part of the President (at the request of Senate Interim Committee on Veterans and Emergency Preparedness)

## SUMMARY

The following summary is not prepared by the sponsors of the measure and is not a part of the body thereof subject to consideration by the Legislative Assembly. It is an editor's brief statement of the essential features of the measure **as introduced**.

Requires facility dispensing Class 1 flammable liquids or diesel fuel to have manually-operated system capable of allowing liquid or fuel dispensing if usual electrical power supply to dispensing device is disrupted. Creates exception.

## A BILL FOR AN ACT

1  
2 Relating to backup systems at fuel dispensaries.

3 **Be It Enacted by the People of the State of Oregon:**

4 **SECTION 1. Section 2 of this 2015 Act is added to and made a part of ORS 480.315 to**  
5 **480.385.**

6 **SECTION 2. (1) Except as provided in subsection (2) of this section, any filling station,**  
7 **service station, garage or other dispensary where Class 1 flammable liquid, except aviation**  
8 **fuel, is dispensed or where diesel fuel is dispensed, including but not limited to nonretail fa-**  
9 **ilities, must have a manually-operated backup system capable of allowing the dispensing of**  
10 **Class 1 flammable liquid or diesel fuel into fuel tanks or other containers if the usual elec-**  
11 **trical power supply to the dispensing devices is disrupted.**

12 **(2) A manually-operated backup system is not required under subsection (1) of this sec-**  
13 **tion for any dispensing device that has a backup electrical power system capable of operating**  
14 **the dispensing device if the usual electrical power supply is disrupted.**

15  

---

  
**NOTE:** Matter in **boldfaced** type in an amended section is new; matter [*italic and bracketed*] is existing law to be omitted. New sections are in **boldfaced** type.