

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT		1. CONTRACT ID CODE	PAGE OF PAGES 1 2
2. AMENDMENT/MODIFICATION NO. 0005	3. EFFECTIVE DATE 04/03/2019	4. REQUISITION/PURCHASE REQ. NO.	5. PROJECT NO. (If applicable)
6. ISSUED BY USDA FOREST SERVICE SIUSLAW NATIONAL FOREST 3200 SW JEFFERSON WAY CORVALLIS OR 97331	CODE 04T0	7. ADMINISTERED BY (If other than Item 6)	CODE
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)		(x) 9A. AMENDMENT OF SOLICITATION NO. 1204T019Q0018	9B. DATED (SEE ITEM 11) 03/19/2019
CODE		10A. MODIFICATION OF CONTRACT/ORDER NO.	
FACILITY CODE		10B. DATED (SEE ITEM 13)	

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers is extended. is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing Items 8 and 15, and returning 1 copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGEMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

13. THIS ITEM ONLY APPLIES TO MODIFICATION OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.

CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor is not. is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

Drift Creek Falls Deck Replacement
Hebo Ranger District
Siuslaw National Forest
Lincoln County, OR

1. Due to a recently found change in the Routine Actions and Maintenance Biological Opinion for USDA Forest Service, et. el. (RAMBO) from the 2016 document to the 2018 document - the use of pressure treated wood with oil-type preservatives such as creosote, pentachlorophenol or copper naphthenate is no longer permitted.

In order for the Drift Creek Falls Deck Replacement Project to comply with the most current Continued ...

Except as provided herein, all terms and conditions of the document referenced in Item 9 A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print) Darcy J. Rapoza, CO	
15B. CONTRACTOR/OFFEROR (Signature of person authorized to sign)	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA /s/ Darcy J. Rapoza (Signature of Contracting Officer)	16C. DATE SIGNED 3 April 2019

CONTINUATION SHEET

REFERENCE NO. OF DOCUMENT BEING CONTINUED
1204T019Q0018/0005

PAGE OF
2 2

NAME OF OFFEROR OR CONTRACTOR

ITEM NO. (A)	SUPPLIES/SERVICES (B)	QUANTITY (C)	UNIT (D)	UNIT PRICE (E)	AMOUNT (F)
	<p>programmatic, the only type of pressure treatment now allowed is the Klear-Gard 25 (or approved equal).</p> <p>Furthermore, the updated language in the programmatic stipulates that pressure treated material exposed to precipitation must be "sealed with a durable water-repellent coating." With this updated information, the durabak-18 requirement will be eliminated from the contract, and contractors will be required to apply a standard water-repellent deck stain/sealant that is clear in color to each deck board. Contractors will need an approved submittal for the deck sealant of their choosing.</p> <p>Lastly, contractors will field treat any holes or cuts made in the field to the deck boards with Outlast Q8 Log Oil - in clear color (or approved equal).</p> <p>2. If the lead time for decking lumber fabrication is projected to go beyond the current time limitations of the contract, the contract time will be extended as needed to incorporate additional time for lumber fabrication and associated delay in timing for bridge work at the project site. The contractor will need to provide proof of lumber fabrication lead time in writing to the CO prior to receiving a contract time extension.</p>				